

Village of Goodfield

Water and Sewer Committee Meeting

August 29, 2016 at the Village Hall (7:00 p.m.)

Committee Chairman Wade Wettstein called the meeting to order at 7:00 p.m. Committee members Terry Nohl and Todd Perry were present. Also present were Public Works Administrator Josh Nohl, Assistant PWA Mike Carr, Water Operator Brad Bode, Engineer Duane Yockey, Engineer Ed Duran and Clerk Sheri Martin.

The agenda was to discuss water quality at tower 2.

The Village is required to test for disinfection by-products and in April the Village had a high sample on haloacetic acid at tower 2. A public notice will be sent out to all residents. OEL paper work will be sent to EPA, stating how we will correct the problem.

Engineer Ed Duran just came from testing tower 2 for stratification. Ed said there is no stratification in tower 2 at this time. Ed thinks it takes approximately 18 hours to turn over in tower 2.

Brad Bode, water operator said it is hard to keep the water chlorinated with the warmer temperature in the tower.

Engineer Yockey said we need to keep the water turning over. Another thing we can do is get rid of more components at the Water Treatment Plant. He is not sure mixing is the problem if the tower is not stratified. Other options could be to:

- Change the amount of chlorine used
- Reduce the amount of ammonia
- Change the pumping
- Change the amount of resin

Ed asked if the Village has made any changes with the wells we use. Brad Bode said there have been no changes.

Currently there is no alarm dialer on the Miex unit. It would be good to put the alarm dialer on the Miex unit.

Because our last test was so low Engineer Yockey wondered if we should wait and see what happens with testing. This may have just been one bad sample.

Motion was made by Perry, seconded by Nohl to recommend:

1. Changing tower levels in tower 2
2. Having Orica come out and change programming/alarm dialer
3. Look into getting internet at the Water Treatment Plant

It was the consensus of the Committee to take monthly samples for a while.

Motion was made by Nohl, seconded by Perry to adjourn meeting. Meeting adjourned at 8:00p.m.

Wade Wettstein, Chairman